



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services
Asansol Fire Station, G.T. Road, P.O.: Asansol,
P.S.: Asansol(South), Pin :- 713301

Memo no.: IND/WB/FES/20182019/16939

Date: 18-03-2024

From:
Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services

To: Durgapur Public School,
Mouza - Gopinathpur, C.S Plot No.214(P), J.I no.85, Ward no. C/27, Under D.M.C, Sahid Sukumar Benerjee Sarani,
Bidhan Nagar, P.s- NTPS Durgapur, Dist. Paschim Bardhaman, Pin- 713212.

Sub: Renewal of fire safety Certificate for the occupancy of an existing Construction G+3 storied Educational Building in favor of Durgapur Public School , Mouza - Gopinathpur, C.S Plot No.214(P), J.I no.85, Ward no. C/27, Under D.M.C, Sahid Sukumar Benerjee Sarani, Bidhan Nagar, P.s- NTPS Durgapur, Dist. Paschim Bardhaman, Pin- 713212.

This is in reference to your application no. 0125191239100395 dated 19-01-2024 regarding the Renewal of fire safety Certificate for the occupancy of an existing Construction G+3 storied Educational Building in favor of Durgapur Public School , Mouza - Gopinathpur, C.S Plot No.214(P), J.I no.85, Ward no. C/27, Under D.M.C, Sahid Sukumar Benerjee Sarani, Bidhan Nagar, P.s- NTPS Durgapur, Dist. Paschim Bardhaman, Pin- 713212.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

NOTE - RFSC issuance on condition that standby pump to be provided within three months.


1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.

The authenticity of this document can be verified by accessing the URL: www.wbfire.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191239100395.


Page : 1

On Behalf
19/03/2024

1. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.
2. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
3. Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above mentioned system.
4. Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
5. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
6. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
7. First aid firefighting system shall be provided as per I.S specification.
8. The notice of firefighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
9. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
10. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
11. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety Installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
12. The Renewal of Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid

Date: 10/04/2024

Divisional Fire Officer Pachim Bardhaman Division...
Pachim Bardhaman
West Bengal Fire & Emergency Services


10/04/2024

Principal
DURGAPURI PUBLIC SCHOOL
BODH GAYA - 845132
JHARKHAND - 845132
ANNAU - 845132